

Addendum No. 3

Bid No. 19/20-02MO, University High School High Voltage Replacement

March 31, 2020

Addendum No. 3 forms a part of the contract and modifies the original bid documents. It is intended that all work affected by the following modifications shall conform to related provisions, project schedule, project manual/specifications, general conditions and drawings of the contract, of the original bid documents. **Modify the following items wherever appearing in any portion of the bid documents. Acknowledge receipt of Addendum No. 3 in the space provided on this form as well as on the Bid Form. Failure to do so may subject bidder to disqualification.**

Changes and/or Additions to Bid Documents

3.1 Addendum No. 2, Item 2.2.2 Responses to RFI's, No. 6 – Revise response to read as follows:

RESPONSE: All field testing as indicated in the original specification is required, including but not limited to Shield Continuity Testing, Insulation Resistance Testing, Dielectric Withstand Either VLF/Tan Delta or VLF, and Partial Discharge Testing. The only exception is the requirement for wind tunnel testing at 100 MPH. No wind tunnel testing is required for this project.

ALL OTHER PROVISIONS of the original bid documents shall remain unchanged.

SIGN AND RETURN THIS ADDENDUM NO. 3 WITH YOUR PROPOSAL.

Bid Due Date: April 6, 2020 at 2:00 pm.

Company Name

Print Name and Title

Signature

Date